

## Producer Statement Construction (PS3) Plumbing

The person carrying out the plumbing work should complete this form.

Building Consent No		Certifying Plumber's Registration No	
Author name			
Author company			
Description of plumbing work			
Legal description			
Site address			

I have sighted the above building consent and read the attached conditions of the consent. I confirm that the plumbing pipe work and fittings have been selected and constructed to comply with the consented plans.

I confirm that I have personally tested the drainage system by the method indicated below.

- By pressurising the pipe work to 1500 kPa for a period of not less than 15 minutes (NZBC G12/AS1 7.5.1) (AS 3500.4, 11.3 for 30 minutes, AS 3500.5, 2.23.1 for 30 minutes) for both hot and cold water and checking to see that there are no leaks
- By pressurising the uPVC cold water pipe work to 1.5 times the maximum working pressure for a period of not less than 15 minutes and checking to see that there are no leaks (NZBC G12/AS1, NZS 7643 9.3.2)
- By pressurising the pipe work in accordance with the manufacturer's requirements (Note – the most robust test must be used)

Test report attached  Yes  No

I understand that this producer statement, if accepted, will be relied on by Council for the purposes of establishing compliance with the above building consent.

Plumber's contact details

Signature		Date	
Address			
Phone		Mobile	
Email			

### Council Use Only

Register checked	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Registration current	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Producer statement accepted as establishing compliance with the consented plans	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Officer's name		Date

Producer statements are accepted solely at Upper Hutt City Council's discretion.